

Generator Installation



Village of Hoffman Estates

Code Enforcement
1900 Hassell Road
Hoffman Estates, IL 60169
(847) 781-2631

www.hoffmanestates.org/permits

Submittal Requirements:

- A copy of the plat of survey with the location and dimensioned distances from property lines, the principal structure and any other structures, and other equipment must be indicated.
- A copy of the manufacturer's specifications for generator and equipment installation must be submitted.

Code Requirements:

- Call J.U.L.I.E. (811) for utility locating.
- Manufacturer's clearances must be followed but in no case shall a generator be closer than 18 inches away from any structure.
- The generator shall be located at least 3 feet from the property line and may not be located in easements.
- All applicable building codes shall be followed. To find a list of applicable building codes, please visit www.hoffmanestates.org
- Steel and black iron pipe installed below grade shall be wrapped with an approved electrochemical corrosion-resistant pipe wrap.
- All piping shall be protected from damage and be located to prevent tripping and contact hazards.

Inspections:

- Contracted electrician must be on site for all inspections.
 - Natural Gas piping and electrical inspections shall be made prior to covering/burying it.
 - A final inspection upon completion of work.
 - Additional inspections may be required.
-