



# HOFFMAN ESTATES

---

GROWING TO GREATNESS

March 14, 2024

**SUBJECT: VILLAGE OF HOFFMAN ESTATES  
2024 STREET REVITALIZATION PROJECT #2  
ADDENDUM NO. 1**

To Whom It May Concern,

Please note the following **changes** to the above contract:

GATE VALVE 8" WITH VAULT, 5' DIAMETER

This work shall consist of furnishing and installing a water valve in vault at the locations specified on the plans and in accordance with the "Valve Vault Detail".

Water Valves

All valves shall be iron body, resilient seated, bronze mounted, nonrising stem gate valves conforming to **AWWA C515** requirements, and shall be installed per the requirements of Section 42 of the Standard Specifications for Water and Sewer Main Construction in Illinois. Valves shall be **Mueller A-2361** with stainless trim or approved equal.

Valve Vault

This work includes furnishing and installing a valve vault at locations shown on the Plans and as directed by the Engineer in accordance with Section 602 of the Standard Specifications.

Valve vaults shall consist of precast reinforced concrete sections meeting ASTM C-478 and ASTM C-443 standards, and shall conform to the Village detail titled "Valve Vault Detail" included in the plans. Adjusting rings shall be precast concrete rings. The total number of adjusting rings shall not exceed two for a maximum height of 12 inches. Vault steps shall be polypropylene plastic manufactured by M.A. Industries (PSI-PF) or approved equal. Flexible boots, meeting ASTM C-923, are required at all pipe openings. When placed within concrete pavement, the structure shall be boxed out with ¾" expansion material.

The pressure connection to the existing watermain is included in the valve vault pay item.

Basis of Payment

This work shall be paid for at the contract unit price per each for GATE VALVE 8" WITH VAULT, 5' DIAMETER and shall include all work described above and the "Valve Vault Detail".

**THESE CHANGES TO THE ABOVE DOCUMENTS MUST BE REFLECTED IN THE BIDS SUBMITTED TO THE VILLAGE. THE ABOVE CLARIFICATION HAS BEEN MADE TO ASSIST YOU IN PREPARING YOUR PROPOSAL.**

**PLEASE SIGN BELOW TO VERIFY RECEIPT OF THE ADDENDUM AND RETURN WITH YOUR BID.**

Company/Bidder: \_\_\_\_\_

Date: \_\_\_\_\_

Name & Title: \_\_\_\_\_

Signature: \_\_\_\_\_

Sincerely,

A handwritten signature in blue ink, appearing to read 'Andy LoBosco', with a long horizontal flourish extending to the right.

Andy LoBosco, P.E.  
Senior Project Manager