September 26, 2024

SUBJECT: VILLAGE OF HOFFMAN ESTATES

2024 STORM SEWER REHABILITATION

**CLARIFICATIONS AND RESPONSE TO QUESTIONS** 

To Whom It May Concern:

This letter is meant to clarify some questions and concerns regarding the 2024 Storm Sewer Rehabilitation Project. This is not considered an addendum, but an additional resource for your information and consideration.

- 1. The Village understands that some of the construction activities related to the curing process of the liner will need to extend beyond the allowable Village construction working hours. The contractor will need Village approval prior to any deviations from these permitted work hours.
- 2. The Village will allow for alternate bids to be submitted that may include the use of alternate materials/methods (i.e. spray applied liner). However, bidders must also respond to the full bid as proposed. Alternate materials/methods will not be reviewed or approved by the Village prior to the bid opening but will be evaluated with all bids.
- 3. Hydrant meters are available for use. See attached for hydrant permit info. <a href="https://www.hoffmanestates.org/home/showpublisheddocument/21972/638385912692970">https://www.hoffmanestates.org/home/showpublisheddocument/21972/638385912692970</a>
  <a href="https://www.hoffmanestates.org/home/showpubl
- 4. Debris must be removed and disposed of off-site.
- 5. ASTM F1216 is mentioned in your specification which allows for both water and steam curing. Can you confirm that curing can be accomplished through water or steam curing on your project?

Yes, either method is acceptable. ASTM F2019 which specifies the UV-Light curing method is also acceptable.

6. While reviewing the specification I did not see a specification of Warranty period/correction period after substantial completion neither a specific amount of Liquidated damages to be paid if past due on final completion. Please advise.

Liquidated damages will follow the schedule per IDOT Standard Specifications for Road and Bridge Construction (adopted January 1, 2022) Article 108.09. No warranty specification is included.

The above clarifications have been made to assist you in preparing your bid. Thank you for your consideration.

Sincerely.

Oscar Gomez, P.E. Civil Engineer II