

COMMITTEE AGENDA ITEM

VILLAGE OF HOFFMAN ESTATES

SUBJECT: 30-Day Progress Report from Commonwealth Edison Regarding the Status of Resident Issues Concerning Power Service

MEETING DATE: April 23, 2012

COMMITTEE: Public Works & Utilities

FROM: Daniel P. O'Malley, Deputy Village Manager
Joseph Nebel, Director of Public Works

PURPOSE: For Commonwealth Edison to provide a 30-day status reports on resident issues concerning power service as discussed at previous Public Works & Utilities Committee meetings.

BACKGROUND: You will recall on August 29, 2011, Commonwealth Edison appeared at the Special Public Works & Utilities Committee meeting to discuss the cause and remedies regarding numerous and lengthy power outages throughout the Village due to storms in June and July 2011. At that meeting, several residents raised other power issues and ComEd agreed to investigate those issues and report back to the Committee. ComEd appeared at both the October 24 and December 12, Public Works & Utilities Committee meetings with information on the proposed improvements. As the Committee requested ComEd attended the February 27, 2012 meeting and is to continue to provide 30-day progress reports.

DISCUSSION: Attached to this agenda item is the Commonwealth Edison 30-day progress update as provided to staff.

RECOMMENDATION: For discussion purposes.

**POST STORM/POCKET RELIABILITY FOLLOW UP
FOR THE VILLAGE OF HOFFMAN ESTATES**

| COMMUNITY/AREA | FEEDER | OUTAGE HISTORY/CAUSE | RESOLUTION | PROJECTED START | PROJECTED COMPLETION |
|----------------------------------|---------------|--|--|------------------------|-----------------------------|
| DRESDEN & HAMAN | E0210 | 2011-07-23 /TREE/VEGETATION RELATED | SWITCH TO FEEDER E147 | 5/15/12 | 5/31/12 |
| WESTBURY & HAYMAN | | 2011-07-11/TREE/VEGETATION RELATED | | | |
| | | 2011-06-21/TREE/VEGETATION RELATED | | | |
| | | 2011-05-25/INTENTIONAL UNSCHEDULED | INSTALL 3 TRIP SAVERS | COMPLETE | COMPLETE |
| | | 2010-10-27 /TREE/VEGETATION RELATED | | | |
| | | 2010-01-03/EQUIPMNT/MATERIAL FAILURE | | | |
| | | 2009-10-06/TREE/VEGETATION RELATED | TARGET TREE TRIMMING | COMPLETE | COMPLETE |
| | | 2009-10-06/WEATHER RELATED | | | |
| | | 2009-07-28/TREE/VEGETATION RELATED | | | |
| HILLCREST | E148 | 2011-07-23/TREE/VEGETATION RELATED | INSTALL 1400' OF HENDRIX CABLE | 3/26/12 | 4/26/12 |
| | | 2011-07-11/TREE/VEGETATION RELATED | | | |
| | | 2011-06-21/WEATHER RELATED | | | |
| | | 2009-03-29/TREE/VEGETATION RELATED | | | |
| | | | REPLACE 1550' URD | 1/24/12 | 5/31/12 |
| | | | | | |
| | | | TARGET TREE TRIMMING | COMPLETE | COMPLETE |
| E THACKER | E5317X | 2011-07-11/TREE/VEGETATION RELATED | INSTALLATION OF BYPASS FUSE ON FEEDER | 4/9/12 | 5/15/12 |
| | | 2011-06-/WEATHER RELATED | | | |
| | | 2011-05-17 /WILDLIFE | | | |
| | | 2010-06-18 /WEATHER RELATED | | | |
| | | 2010-05-08 /EQUIPMNT/MATERIAL FAILURE | TARGET TREE TRIMMING | COMPLETE | COMPLETE |
| | | 2009-10-06 /WEATHER RELATED | | | |
| | | 2009-07-28 /WEATHER RELATED | | | |
| | | 2009-06-19/WEATHER RELATED | | | |

| COMMUNITY/AREA | FEEDER | OUTAGE HISTORY/CAUSE | RESOLUTION | PROJECTED START | PROJECTED COMPLETION |
|---|---------------|--|--|------------------------|-----------------------------|
| BERKLEY & WASHINGTON | E141Y | 2011-08-26 /INTENTIONAL UNSCHEDULED | TARGET TREE TRIMMING | COMPLETE | COMPLETE |
| | | 2011-07-11 /TREE/VEGETATION RELATED | | | |
| | | 2011-03-01 /EQUIPMNT/MATERIAL FAILURE | INSTALL TRIP SAVERS (3) | COMPLETE | COMPLETE |
| | | 2009-06-22 /EQUIPMNT/MATERIAL FAILURE | | | |
| | | (SAME EQUIPMENT MULTIPLE OUTAGES) | | | |
| CRESCENT LN | E141Y | 2011-11-20 /UNKNOWN (wire down) | NO ACTION – OUTAGES WERE UNIQUE & NOT CHRONIC | N/A | N/A |
| | | 2011-11-18 /TREE/VEGETATION RELATED | | | |
| | | 2011-05-17 /EQUIPMNT/MATERIAL FAILURE | | | |
| | | 2009-02-16 /EQUIPMNT/MATERIAL FAILURE | | | |
| | | (DIFFERENT SECTIONS OF CABLE) | | | |
| MOHAVE/NEWTON | E141Y | 2011-08-26 /INTENTIONAL UNSCHEDULED | NO ACTION – OUTAGES WERE UNIQUE & NOT CHRONIC | N/A | N/A |
| | | 2011-06-21 /TREE/VEGETATION RELATED | | | |
| | | 2011-03-01 /EQUIPMNT/MATERIAL FAILURE | | | |
| | | 2011-02-20 /WILDLIFE | | | |
| PARKVIEW CIRCLE (I USED 2013 W PARKVIEW CIR) | E1415 | 2011-08-21 /INTENTIONAL UNSCHEDULED | TARGETED TREE TRIMMING AROUND PARKVIEW CIRCLE. | COMPLETE | COMPLETE |
| | | 2011-08-20 /WEATHER RELATED | | | |
| | | 2010-10-02 /EQUIPMNT/MATERIAL FAILURE | INSTALLATION OF TRIP SAVERS AT 2 LOCATIONS | COMPLETE | COMPLETE |
| | | 2010-03-14 /EQUIPMNT/MATERIAL FAILURE | | | |

| COMMUNITY/AREA | FEEDER | OUTAGE HISTORY/CAUSE | RESOLUTION | PROJECTED START | PROJECTED COMPLETION |
|---|--------|---|--|-------------------------|-------------------------|
| CASTAWAY LANE EXCESSIVE MOMENTARIES; THE MAJORITY WERE RELATED TO DISTRIBUTION AUTOMATION WORKING PROPERLY. THE METER DIDN'T CAPTURE ANY IRREGULARITIES (Nov. 2011) | E0225 | 2011-07-23 /WEATHER RELATED 2010-08-19 /INTENTIONAL SCHEDULED 2010-08-18 /EQUIPMNT/MATERIAL FAILURE 2010-08-09 /TREE/VEGETATION RELATED 2009-10-30 /TREE/VEGETATION RELATED 2009-08-28 /INTENTIONAL UNSCHEDULED 2009-07-28 /INTENTIONAL UNSCHEDULED 2009-06-20 /TREE/VEGETATION RELATED 2009-06-20 /EQUIPMNT/MATERIAL FAILURE 2009-06-19 /EQUIPMNT/MATERIAL FAILURE 2009-06-19 /EQUIPMNT/MATERIAL FAILURE | TARGET TREE TRIMMING & SWITCHING TO E3314 (THIS WILL FACILITATE LOAD BALANCING) | COMPLETE 5/15/12 | COMPLETE 5/31/12 |